

**QUESTIONS AND RESPONSES  
FOR  
RECOVERY – FTQW062435 – Replace Well Pump (B1139)  
AT  
EIELSON AIR FORCE BASE, ALASKA**

**Solicitation Number: FA5004-09-T-C001**

It shall be noted to all interested parties that the following questions have been received in writing regarding the subject acquisition. Additionally, responses have been provided to the below listed questions.

As a reminder, it is the responsibility of all Interested Parties to review this website (<http://www.fedbizopps.gov>) frequently for any updates and/or amendments to any and all subject documents.

**Question:**

What is the Model Number for Fairbanks Morse Pump?

**Response:**

Model Number is 7000. The Specifications have been changed in Statement of Work within the Solicitation; see Amendment 0002.

**Question:**

If the contractor is unable to find an exact duplicate for the pump, would the Government consider another equal as long as it did not conformise the specifications required for the original purpose of the well?

**Response:**

The Caveat is Buy American, so no pumps from anywhere else without a waiver. Otherwise, any other pump that is equivalent to the Fairbanks Morse, which meets the same performance criteria, is sufficient.